



APPROVED

# Certificate of Compliance

This certificate is issued for the following:

MODEL A61 SPRINKLER SYSTEM ALARM TEST DEVICE

SIZE 2 INCH NPS

NOMINAL K-FACTORS: 4.2, 5.6, 8.0, 11.2, 14.0, 16.8, 22.4 AND 25.2

Prepared for:

Giacomini S.p.A  
Via per Alzo, 39  
28017 S Maurizio d'Opaglio - NO  
Italy

Manufactured at:

Giacomini S.p.A  
Via per Alzo, 39  
28017 S Maurizio d'Opaglio - NO  
Italy

FM Approvals Class: 1625, "Sprinkler System Alarm Test Devices"

Approval Identification: 3037609

Approval Granted: February 3, 2010

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.*

Richard Dunne

Manager - Hydraulics

FM Approvals

743 Reynolds Road

West Gloucester, RI 02814



Member of the FM Global Group

February 3, 2010