

CERTIFICATE OF COMPLIANCE

Certificate Number EX4430
Report Reference EX4430-1992-06-08
Date 2022-September-26

Issued to: GIACOMINI SPA
VIA PER ALZO 39
S MAURIZIO D'OPAGLIO NO 28017 IT

**This is to certify that
representative samples of**

DRAIN FITTINGS, SPECIAL TYPE
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/CAN/UL 258 - Shutoff Valves for Trim and Drain
Purposes for Fire Protection

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX4430
Report Reference EX4430-1992-06-08
Date 2022-September-26

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model A61 test and drain fitting in the following nominal sizes, discharge coefficients and rated pressures:

Size, in.	Nominal K-Factor, gpm/(psi) ^{1/2}	Rated Pressure, psig
1	2.8, 4.2, 5.6, 8.0, 14.0	300
1-1/4	2.8, 4.2, 5.6, 8.0, 11.2, 14.0	300
1-1/2	4.2, 5.6, 8.0, 11.2, 14.0, 16.8, 22.4, 25.2	300
2	4.2, 5.6, 8.0, 11.2, 14.0, 16.8, 22.4, 25.2	300

Model A62 test and drain fitting in the following nominal sizes, discharge coefficients and rated pressures:

Size, in.	Nominal K-Factor, gpm/(psi) ^{1/2}	Rated Pressure, psig
1-1/4	2.8, 4.2, 5.6, 8.0	300
2	4.2, 5.6, 8.0, 11.2, 14.0, 16.8, 22.4, 25.2	300



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>