


Modular manifold in technopolymer, with flow meters

Datasheet
1019EN 04/2026



Pre-assembled modular manifold for HVAC systems, made of technopolymer, composed of:

- 1 supply manifold with flow meters (double scale: 0÷5 l/min and 0÷1,5 GPM) with fluid adjustment/shut-off function;
- 1 return manifold with shut-off valves with manual handwheel (connection M30 x 1,5 mm), pre-arranged for thermo-electric command via R473/R473M actuators that can be installed after fitting the relative ring nut R453FY002 (included with the kit) on the module;
- 2 multi-function valves R269T (supply and return);
- brackets R588FP with spacer on the return.

Versions and product codes

PRODUCT CODE	CONNECTIONS: MANIFOLD x OUTLETS	No. OUTLETS	CABINETS L x H x D
R553FP302	G 1" x 3/4"E	2	R500Y111 R500Y221 R500Y231
R553FP303		3	R500Y111 R500Y221 R500Y231
R553FP304		4	R500Y112 R500Y222 R500Y232
R553FP305		5	R500Y112 R500Y222 R500Y232
R553FP306		6	R500Y112 R500Y222 R500Y232
R553FP307		7	R500Y112 R500Y222 R500Y232
R553FP308		8	R500Y113 R500Y223 R500Y233
R553FP309		9	R500Y113 R500Y223 R500Y233
R553FP310		10	R500Y113 R500Y223 R500Y233
R553FP311		11	R500Y114 R500Y224 R500Y234
R553FP312		12	R500Y114 R500Y224 R500Y234

Optionals

- R500-1, R500-2, R500-2C: metal cabinets with adjustable depth
- R473, R473M: normally closed thermo-electric actuator
- R73FPY001: pair of spanners for removing the manifold modules
- R178E, R179E: 3/4"E adaptors

Spare parts

- R588FPY001: bracket with supports and spacer on the return
- R453FY002: plastic ring nut M30 x 1,5 mm for installing the thermo-electric actuators
- P553FPY011: supply module with flow meter and 3/4"E outlet
- P553FPY012: return module with valve and 3/4"E outlet
- P553FPY005: cap module
- P553FPY006: inlet module (without nut)
- P553FPY030: kit composed of supply module + return module with 3/4"E outlets
- P583Y004: nut and gasket for inlet module
- P10HFPY001: valve body for the return module, connection M30 x 1,5 mm for installing the thermo-electric actuators


Technical data

- Fluids: water, glycol solutions (max. 30 %)
- Temperature range: 5÷60°C
- Max. operating pressure: 6 bar (10 bar for system testing)
- Center distance between the outlets: 50 mm
- Flow meters with double scale (0÷5 L/min and 0÷1,5 GPM)

Materials

- Manifolds: internal and external structure in technopolymer
- Multifunction valves R26gT: brass UNI EN 12165 CW617N
- Gaskets: EPDM

Losses of pressure



No. of turns flow meter ring nut	F.O.
Kv	1,05

Main characteristics

Supply manifold with flow meters

The supply manifold is fitted with double-scale flow meters (0÷5 L/min and 0÷1,5 GPM), that also have a fluid adjustment/shut-off function.

To adjust the opening of the circuits, remove the protective red cap then rotate the black ring nut manually.

Return manifold with shut-off valves with manual handwheel

The return manifold is fitted with shut-off valves with a manual handwheel, pre-arranged for thermo-electric command via the R473/R473M (normally closed) actuators that can be installed after fitting the relative ring nut R453FY002 on the module (refer to the "Installation" paragraph).


Multi-function valves R26gT

The R26gT multi-function valves are designed for installation upstream of the manifold distribution bars.

They perform the following functions:

- shut-off ball valve;
- automatic air vent valve fitted with a shut-off valve;
- system filler/drain cock;
- contact thermometer;
- inlet for immersion temperature probe Ø 6 mm.

Components




- 1 Supply manifold with outlets equipped with flow meters
- 2 Return manifold with outlets with a shut-off valve
- 3 Multifunction valves equipped with drain cock, automatic air vent valve, thermometer and shut-off ball valve
- 4 Brackets R588FP with spacer on the return
- 5 Clip for fixing the eccentric fitting

► Installation

▲ WARNING The installation must be carried out by qualified personnel, following the instructions provided in the package.

Pipe inlet from the left




The manifold is supplied pre-assembled on the R588FP brackets, and pre-arranged for connecting R269T multi-function valves with left connection (recommended configuration).


The R269T multi-function valves are supplied in boxes, with the components disassembled.

To assemble them, first of all assemble the air vent valve, the thermometer and the drain cock on the main body, then connect the unit to the distribution manifold using the nut and gasket.

▲ WARNING The manifold can only be installed on the R588FP brackets, so these must never be replaced with other models.







Pipe inlet from the right



Depending on system requirements, the R269T multi-function valves can also be installed to the right of the manifold.

In this case, proceed as follows:

- 1) open the supports with clip connection and remove the manifolds from the brackets;
- 2) rotate the manifolds by 180°;
- 3) replace the manifolds on the brackets and close the supports with clip connection;
- 4) the R269T multi-function valves are supplied in boxes, with the components disassembled. To assemble them, first of all assemble the air vent valve, the thermometer and the drain cock on the main body, then connect the unit to the distribution manifold using the nut and gasket.



NOTE. Thanks to the eccentric fittings, even in the installation with piping inlet from the right, the connection of the pipe's system circuits will be easy and practical.

NOTE. In the package of the multifunction valves there are also screws, to be used if necessary to more securely close the supports with clip hooks.

WARNING In the case of installation with pipe inlet from the right, the thermometer of the R269T multi-function valves is assembled in the lower part of the main body, as shown in the figure.

WARNING In the case of installation with pipe inlet from the right, the adaptor clips (components - ref.5) will not be accessible because they will be facing towards the inside of the cabinet.

WARNING The manifold can only be installed on the R588FP brackets, so these must never be replaced with other models.

➤ Assembling/disassembling the modules


⚠ WARNING The module assembly/disassembly operations must take place in a free, accessible place with the manifold NOT connected to the system pipes and NOT supported on the relative brackets.

⚠ WARNING. The module assembly/disassembly operations must be carried out only in case of real necessity in order not to risk compromising the hydraulic seal.

The manifold is supplied pre-assembled, but new modules can be added or existing ones removed.


To **disassemble** a module, proceed as follows:

- 1) open the supports with clip connection and remove the manifolds from the brackets;
- 2) position one of the two R73FPY001 spanners in the front part of the module and the other in the rear part, so that the protrusions "A", "B" and "C" of the spanners slide into the slots "A", "B" and "C" on the module;
- 3) press one spanner at a time against the module to raise the fins "C" and rotate the module, so that it can be disassembled from the first side; when doing this, be careful not to lose or damage the O-Ring "D";
- 4) repeat steps 2 and 3 to disassemble the second side of the module that needs to be removed;
- 5) after removing the module, reassemble the manifold:
 - make sure the O-Ring "D" is correctly inserted on the male fitting of the module (pushed down as far as it will go), lubricating it with a suitable lubricant for the material (EPDM) and for the intended use of the system (eg. silicone lubricants). During this operation pay attention to lubricate the O-Ring only and not the adjacent plastic parts;
 - insert the module with the male fitting in the corresponding female fitting of the adjacent module (rotated by about 45°);
 - rotate both modules to align them, ensuring that protrusion "E" slides into slots "A" and "B" and protrusion "F" slides into slot "C" until a click is heard;
- 6) replace the manifolds on the brackets and close the supports with clip connection.



To **assemble** a new module, proceed as follows:

- 1) open the supports with clip connection and remove the manifolds from the brackets;
- 2) position one of the two R73FPY001 spanners in the front part of the module and the other in the rear part, so that the protrusions "A", "B" and "C" of the spanners slide into the slots "A", "B" and "C" on the module;
- 3) press one spanner at a time against the module to raise the fins "C" and rotate the module, so that it can be disassembled from the first side; when doing this, be careful not to lose or damage the O-Ring "D";
- 4) insert the new module, then reassemble the manifold:
 - make sure the O-Ring "D" is correctly inserted on the male fitting of the module (pushed down as far as it will go), lubricating it with a suitable lubricant for the material (EPDM) and for the intended use of the system (eg. silicone lubricants). During this operation pay attention to lubricate the O-Ring only and not the adjacent plastic parts;
 - insert the module with the male fitting in the corresponding female fitting of the adjacent module (rotated by about 45°);
 - rotate both modules to align them, ensuring that protrusion "E" slides into slots "A" and "B" and protrusion "F" slides into slot "C" until a click is heard;
- 5) replace the manifolds on the brackets and close the supports with clip connection.






► Regulating the system circuits

Regulating the supply manifold

The individual system circuits are regulated via the flow meters on the supply modules (that also act as adjustment lockshield). To make the adjustment proceed as follows:

- 1) remove the protective red cap;
- 2) manually rotate the black ring nut at the base of the flow meter to open or close the circuit; the desired flow rate value can be read by the graduated scale of the flow meter;
- 3) when the adjustment is complete, refit the red protective cap.







Regulating the return manifold


The individual circuits are regulated on the return outlets, either manually - by turning the blue handwheel - or by installing normally closed R473/R473M thermo-electric actuators.

To install the thermo-electric actuators proceed as follows:


- 1) remove the blue handwheel and tighten the R453FY002 ring nut with M30 x 1,5 mm connection (included in the kit);
- 2) assemble the thermo-electric actuator on the ring nut, pressing just enough to lock them together;
- 3) turn the actuator about 15° clockwise until a click is heard (max. torque 5 Nm). To release the actuator, turn it 15° counterclockwise;
- 4) press the red lockout button and make the electrical connection of the actuator, following the wired diagram supplied with the actuator instructions.



⚠ WARNING. To allow the installation in case of pipe inlet from the right, the thermo-electric actuators must be mounted with the red button facing the inside of the cabinet.



➤ Connecting the system circuits




⚠ WARNING. When tightening the adaptor it is necessary to use a backup spanner to hold the manifold fitting in stationary.

To connect the system circuit pipes use suitable adaptors for copper, plastic or multilayer pipes from the R178E and R179E (Eurocone) series.

📌 NOTE. Thanks to the eccentric fittings, even in the installation with piping inlet from the right, the connection of the pipe's system circuits will be easy and practical.

➤ Dimensions



PRODUCT CODE	N° STACCHI	A [mm]	B [mm]	C [mm]	D [mm]	E [mm]	F [mm]	G [mm]	H [mm]	I [mm]	L [mm]	M [mm]	N [mm]	O [mm]	P [mm]	Q [mm]	R [mm]	S [mm]	T [mm]	U [mm]
R553FP302	2											258	-		283					
R553FP303	3											308	50		333					
R553FP304	4											358	100		383					
R553FP305	5											408	150		433					
R553FP306	6											458	200		483					
R553FP307	7	165	3/4"E	43	95	209	101	G 1"F	405	50	508	202	250	25	533	100	140	44	65*	111*
R553FP308	8										558		300		583					
R553FP309	9										608		350		633					
R553FP310	10										658		400		683					
R553FP311	11										708		450		733					
R553FP312	12										758		500		783					

* Dimension with plastic spacer (thickness 18 mm) installed on the return bracket. It's possible to remove the spacer in case of installation needs.

➤ Product specifications

R553FP with 3/4"E outlets

Pre-assembled modular manifold in technopolymer, with flow meters. Connections: 1" (R26gT) x DN32 (manifold) x 3/4"E (outlets). Center distance between the outlets: 50 mm. Temperature range: 5÷60°C. Max. operating pressure: 6 bar (10 bar for system testing). Composed of: 1 supply manifold in technopolymer, with flow meters (double scale: 0÷5 L/min and 0÷1,5 GPM) with fluid adjustment/shut-off function; 1 return manifold in technopolymer, with shut-off valves with a manual handwheel, pre-arranged for thermo-electric command; EPDM gaskets; 2 brackets; 2 multi-function valves in brass CW617N (supply and return).

⚠ Safety Warning. Installation, commissioning and periodical maintenance of the product must be carried out by qualified operators in compliance with national regulations and/or local standards. A qualified installer must take all required measures, including use of Individual Protection Devices, for his and others' safety. An improper installation may damage people, animals or objects towards which Giacomini S.p.A. may not be held liable.

♻ Package Disposal. Carton boxes: paper recycling. Plastic bags and bubble wrap: plastic recycling.

ℹ Additional information. For more information, go to giacomini.com or contact our technical assistance service. This document provides only general indications. Giacomini S.p.A. may change at any time, without notice and for technical or commercial reasons, the items included herewith. The information included in this technical sheet do not exempt the user from strictly complying with the rules and good practice standards in force.

♻ Product Disposal. Do not dispose of product as municipal waste at the end of its life cycle. Dispose of product at a special recycling platform managed by local authorities or at retailers providing this type of service.