

GIACOMINI S.p.A. Tel. (+39) 0322 923111 Fax (+39) 0322 96256

Fax (+39) 0322 923111 Fax (+39) 0322 96256 info@giacomini.com www.giacomini.com Sede legale ed amministrativa: Vía per Alzo, 39 - 28017 San Maurizio d'Opaglio (NO) ITALIA R.E.A. della CCIAA di Novara n. 194845 PIVA 01792290031 - Codice Fiscale 01856080062 Identificativo IVA IT 01792290031 Capitale Sociale: € 50.666.520 i.v.

iamento della Alberto Giacomini Holding S a s. di Alberto Giacon



SUPPLIER DECLARATION (Dich1_05_07_01_EN)

(according to UNI CEI EN ISO/IEC 17050-1:2010)

The Manufacturer **GIACOMINI S.p.A.** located in Italy, San Maurizio d'Opaglio (NO) - Via per Alzo, no. 39, under its own responsibility **ATTESTS** that:

the ball valves of the series R258CC, R258D, R259D destined to be used in the following applications and according to the following use limits:

- Minimum Working Temperature: -20 °C with glycol solution at 50 %,
- Maximum Working Temperature with dry saturated steam: 185 °C with 1,05 MPa (10,5 bar)
- Maximum working pressure at 20°C with water and non-dangerous gases:
 4,2 MPa (42 bar) for dimensions 3/8", ½", ¾" and ø15, ø22
 3,5 MPa (35 bar) for dimensions 1", 1 ¼" and ø28, ø35
- Temperature Range with liquid hydrocarbons: -20÷60 °C
- Maximum working pressure at 20°C with liquid hydrocarbons: 1,2 MPa (12 bar)

are properly designed and manufactured using materials suitable to the distribution of water, non-dangerous gases and liquid hydrocarbons according to the sound engineering practice in use, which ensures the safety of use in compliance with the technical requirements and the specific prescriptions, pertinent and applicable, referred to art.4, par. 3, of PED 2014/68/UE Directive with particular reference to Tab.7 of Annex II – Conformity assessment tables.

The subject valves are also manufactured respecting design and production processes in compliance with requirements of **UNI EN ISO 9001:2015** standard.

Moreover, GIACOMINI S.p.A. company ATTESTS,

that the ball valves here identified, in application of the above-mentioned technical requirements and prescriptions, are not "CE marked" since they have characteristics lower than the limits given at paragraph 1, letters a), b) and c) and at paragraph 2 of PED 2014/68/UE Directive.

The Technical Manager

Eng. Marco Rosa Brusin

San Maurizio d'Opaglio, 12/09/2023

Marco Rosa Orusm