

SUPPLIER DECLARATION (Dich1_05_20_00_EN)

(according to UNI CEI EN ISO/IEC 17050-1:2010 standard)

The Manufacturer **GIACOMINI S.p.A.** located in Italy, San Maurizio d'Opaglio (NO) - Via per Alzo, no. 39, under its own responsibility **ATTESTS** that:

the ball valves of the **R259D series** (product codes R259X003, R259X043, R259X004, R259X005, R259X045, R259X006, R259X007, R259X008, R259Y003, R259Y005, R259Y006, R259Y007, R259Y008, R259Y025, R259Y026, R259Y027, R259ZX003, R259ZX005, R259ZX007) destined to be used in the following applications and according to the following use limits:

- *Fluids: water, glycol solutions (max.50%), non-dangerous gases and liquid hydrocarbons*
- *Minimum working temperature: - 20°C with 50 % glycol solutions;*
- *Maximum working pressure with dry saturated steam: 185 °C at 1,05 MPa (10,5 bar)*
- *Maximum working pressure at 20°C with water and non-dangerous gases:*
42 bar for 3/8", 1/2", 3/4" sizes
35 bar for 1" size
- *Temperature range with liquid hydrocarbons: -20°÷60 °C*
- *Maximum working pressure at 20°C with liquid hydrocarbons: 1,2 MPa (12 bar)*

are properly designed and manufactured using materials suitable to the distribution of water, non-dangerous gases and liquid hydrocarbons according to the sound engineering practice in use, which ensures the safety of use in compliance with the technical requirements and the specific prescriptions, pertinent and applicable, referred to **art.4, par. 3, of PED 2014/68/UE Directive** with particular reference to **Tab.7 of Annex II – Conformity assessment tables**.

The subject valves are also manufactured respecting design and production processes in compliance with requirements of **UNI EN ISO 9001:2015** standard.

Moreover, GIACOMINI S.p.A. company **ATTESTS**,

that the ball valves here identified, in application of the above-mentioned technical requirements and prescriptions, **are not "CE marked"** since they have characteristics lower than the limits given at paragraph 1, letters a), b) and c) and at paragraph 2 of PED 2014/68/UE Directive.

The Technical Manager

Eng. Marco Rosa Brusin



San Maurizio d'Opaglio, 09/04/2025