

GIACOMINI S.p.A.

Tel. (+39) 0322 923111 Fax (+39) 0322 96256 info@giacomini.com www.giacomini.com

Sede legale ed amministrativa: Via per Alzo, 39 - 28017 San Maurizio d'Opaglio (NO) ITALIA R.E.A. della CCIAA di Novara n. 194845 PIVA 01792290031 - Codice Fiscale 01856080062 identificativo VAI T 01792290031 Capitale Sociale: € 50.666.520 i.v.



iento della Alberto Giacomini Holding S a s. di Alberto Giac

SUPPLIER DECLARATION (Dich1 06 47 02 EN)

(according to UNI CEI EN ISO/IEC 17050-1:2010)

The manufacturer GIACOMINI S.p.A. located in Italy, San Maurizio d'Opaglio (NO) - Via per Alzo, n. 39, under its own responsibility ATTESTS that:

the dual-check backflow preventers with controlled reduced pressure zone, BA type, of the R626 and R626FL series, destined to be used in the following applications and according to the following use limits:

Fluids: water

Maximum working temperature: 65°C

Maximum working pressure: 10 bar

are properly designed and manufactured according to UNI EN 12729 and UNI EN 1717 standards, using materials suitable to the distribution of water, according to the sound engineering practice in use, which ensures the safety of use in compliance with the technical requirements and the specific prescriptions, pertinent and applicable, referred to art.4, par. 3, of PED 2014/68/UE Directive with particular reference to Tab.9 of Annex II - Conformity assessment tables.

The dual-check backflow preventers are also manufactured respecting design and production processes in compliance with the requirements of UNI EN ISO 9001:2015 standard.

Moreover, GIACOMINI S.p.A. company ATTESTS

that the dual-check backflow preventers here identified, in application of the above-mentioned technical requirements and prescriptions, are also accompanied by sufficient use instructions and are not "CE marked" since they have characteristics lower than the limits given at paragraph 1, letters a), b) e c) and at paragraph 2 of PED 2014/68/UE Directive.

Signed for and on behalf of Giacomini S.p.A.

Chief Technical & Quality Officer

Eng. Guido Galliani

San Maurizio d'Opaglio, 21/07/2025