

SUPPLIER DECLARATION (Dich1_05_11_04_EN)

(according to UNI CEI EN ISO/IEC 17050-1:2010)

The manufacturer **GIACOMINI S.p.A.** located in Italy, San Maurizio d'Opaglio (NO) - Via per Alzo, n. 39, under its own responsibility **ATTESTS** that:

the ball valves series **R850VW, R850VWS, R851VT, R851VTS, R853VT, R853VWL, R854VT, R854VWL, R859VT** destined to be used in the following applications and according to the following use limits:

- *Temperature range: 5÷110°C for R851VW, R850VWS, R853VWL, R854VWL series;*
- *Temperature range: 5÷110°C with peaks at 120°C for short periods of time only, for R851VT, R851VTS, R853VT, R854VT, R859VT series;*
- *Maximum working pressure at 20°C with water:*

35 bar referring to $\varnothing 15, \varnothing 18, \varnothing 22$
28 bar referring to $DN40, DN50, \varnothing 28, \varnothing 35, \varnothing 42, \varnothing 54$ at 28

are properly designed and manufactured using materials suitable to the distribution of water, according to the sound engineering practice in use, which ensures the safety of use in compliance with the technical requirements and the specific prescriptions, pertinent and applicable, referred to **art.4, par. 3, of PED 2014/68/UE Directive** with particular reference to **Tab.9 of Annex II – Conformity assessment tables**.

The subject valves are also manufactured respecting design and production processes in compliance with the requirements of **UNI EN ISO 9001:2015** standard.

Moreover, GIACOMINI S.p.A. company **ATTESTS**,

that the ball valves here identified, in application of the above-mentioned technical requirements and prescriptions, are also accompanied by **sufficient use instructions and are not “CE marked”** since they have characteristics lower than the limits given at paragraph 1, letters a), b) e c) and at paragraph 2 of PED 2014/68/UE Directive.



San Maurizio D'Opaglio, 10/11/2022

The Technical Manager

Eng. Marco Rosa Brusin
