

GIACOMINI S.p.A.
Tel. (+39) 0322 923111
Fax (+39) 0322 96256
info@giacomini.com
www.giacomini.com

Sede legale ed amministrativa: Via per Alzo, 39 - 28017 San Maurizio d'Opaglio (NO) ITALIA R.E.A. della CCIAA di Novara n. 194845 P.IVA 01792290031 - Codice Fiscale 01856080062 Identificativo IVA IT 01792290031 Capitale Sociale: € 50.666.520 i.v.



Società soggetta a direzione e coordinamento della Alberto Giacomini Holding S.a.s. di Alberto Giacomini

SUPPLIER DECLARATION (Dich1_05_21_02_EN)

(according to UNI CEI EN ISO/IEC 17050-1:2010)

The manufacturer **GIACOMINI S.p.A.** located in Italy, San Maurizio d'Opaglio (NO) - Via per Alzo, n. 39, under its own responsibility **ATTESTS** that:

the ball valves of the series **R913**, **R913L**, **R919** destined to be used in the following applications and according to the following use limits:

Maximum working pressure at 20°C with water and non-dangerous gases:

42 bar for 3/8", ½", ¾" sizes 35 bar for 1" and 1 1/4" sizes

Maximum working pressure at 20°C with liquid hydrocarbons:

12 bar

are properly designed and manufactured using materials suitable to the distribution of water, according to the sound engineering practice in use, which ensures the safety of use in compliance with the technical requirements and the specific prescriptions, pertinent and applicable, referred to art.4, par. 3, of PED 2014/68/UE Directive with particular reference to Tab.9 of Annex II – Conformity assessment tables.

The subject valves are also manufactured respecting design and production processes in compliance with requirements of **UNI EN ISO 9001:2015** standard.

Moreover, GIACOMINI S.p.A. company ATTESTS,

that the ball valves here identified, in application of the above-mentioned technical requirements and prescriptions, are also accompanied by sufficient use instructions and are not "CE marked" since they have characteristics lower than the limits given at paragraph 1, letters a), b) and c) and at paragraph 2 of PED 2014/68/UE Directive.

San Maurizio D'Opaglio, 03/02/2023

The Technical Manager

Eng. Marco Rosa Brusin